

Jordan Civil Defence Approval

In the name of Allah

General Civil Defence Directorate
Fire Prevention and Protection Department

Ref.: ٢٧٩٩/٤/٧٤/٣٧/٥

Arabic date:

Date: October 29th, 2001

MESSRS. Nalbandian & Alawneh Trd. Est.

Your ref.

Your letter ref. (NON) dated July 17th, 2001

Subject: request for approving new fire fighting system Marked
PYROGEN

- 1- This is a primary approval for the supply and install of PYROGEN automatic fire fighting system conditioned with submitting of sample for testing purpose.
- 2- Fire alarm system installed with PYROGEN must be approved.
- 3- NAT shall submit a design calculation sheets for each project they attend to install after having the final approval for PYROGEN.

Best Regards,

On behalf of Brigadier of General Manager of Civil Defence,
Major Eng. Adnan Innabi

Copy to the file no. ٤/٧٤

بسم الله الرحمن الرحيم

المديرية العامة للدفاع المدني

إدارة الوقاية والحماية الذاتية

الرقم : و/٧٤/٣٢ ط / ٢٧٩٦

التاريخ: شعبان ١٤٢٢

الموافق ٢٠٠١

السادة/ مؤسسة نلبنديان وعلاونه التجارية

الإشارة

كتابكم رقم بلا تاريخ ٢٠٠١/٧/١٧ م

١- لا مانع من الموافقة المبدئية على اعتماد نظام الحريق التلقائي (PYROGEN)
شريطة تقديم عينة لغايات الفحص والتقييد بتقرير الدراسة المرفق .

٢- لإجراءتكم لطفاً

واقبلوا الاحترام



المدير العام للدفاع المدني

الرائد المهندس عدنان عنابي

نسخه إلى

- ملف رقم (٧٤ ط) وحسب المنكرة رقم و/٧٤ ط / ٤٩٣ تاريخ ٢٣ / ١٠ / ٢٠٠١ م